

Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Valuer.
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvachari,
Vellore – 632 009.
Phone: 0416 2252260.
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

CERTIFICATE FOR STRUCTURAL SOUNDNESS

STATEMENT ACCOMPANYING FORM – A

Date: 23.05.2025.

1. Door No. of the building. : " EDIFY SCHOOL "
: "DURASAMY MAHADEVAN EDUCATIONAL TRUST"
: S.F.Nos. 65/51A, 65/2B2B, 65/2C2 & 68/1D,
: Ramalai Village and panchayat,
: Gudiyatham Taluk,
: Vellore District - 632 601.
2. Location (Street., Ward No., Name of place, i.e., Corporation / Municipality / Panchayat union / Panchayat / Township : S.F.Nos. 65/51A, 65/2B2B, 65/2C2 & 68/1D,
: Ramalai Village and panchayat,
: Gudiyatham Taluk,
: Vellore District - 632 601.
3. Year of Construction : Ground Floor & First Floor : 2019.
4. Approximate cost of construction as per current rates : ₹ 35,00,000 (Or) ₹ 35 Lakhs
5. Purpose for which the building is used or proposed to be used : Educational purpose
6. Purpose for which the building has hitherto been used : Educational purpose
7. Details of construction of the building :
(Particulars of the foundation, soil, specification of various parts under
I. Foundation : RCC Framed Structure.
II. Basement : RCC Column & Isolated Footing.
III. Super structure : RCC Column , Plinth beam & Brick in CM
IV. Floor : RCC Column & Brick in CM
V. Roof : Ceramic tiles Flooring,
: RCC Roof slab
8. Period for which the licence is required : 20.06.2025 to 19.06.2028 (Three years only).
9. Number of persons to be accommodated : Six Hundred { 600 } pupils only

Date: 23.05.2025.

Place: Vellore - 632 009.



Signature of the Engineer, MoV.,
Er. M. Jagadeesan, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District
#39, 3rd Main Road, Phase-I, TNHB, Sathuvachari,

ANNEXURE TO STATEMENT ACCOMPANYING FORM-A

Certified that thatched buildings are not used for conducting any classess for school premises. If any thatched buildings are constructed after issued of this licence, I/we are held responsible for any fire accident that occurs later and tha I / we are aware that our license will be cancelled and it is a punishable crime.

Further it is certified that no addittion or alteration will be made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the eixsting building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of building originally is changed or altered subsequently.

It is also understood that the conditions of all existing, adjecent / other floor or other buildings of any types within this premises which were not opted/covered for the purpose which the licence was granted would be brought under the risk of my own.

We are well aware of that the underground amenities like water suprms, septic tanks, borewells and open wells should be kept always closed tigid condition for all time safety measures to students / publics.

Place:Vellore.

Signature of the Correspondent

Date: 23.05.2025.

Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Valuer.
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvacahri,
Vellore – 632 009.
Phone: 0416 2252260
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

" EDIFY SCHOOL" RAMALAI VILLAGE.

FORM OF CERTIFICATE OF STRUCTURAL UNDER SUB SECTION (B) OF SECTION OF (4) OF THE TAMILNADU
PUBLIC BUILDING (LOCENSING ACT 1965 TAMILNADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE
TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I certify that I have inspected the building mentioned in the statement and I furnish below its salient technical features.

- | | | |
|---|--|-------------------------------------|
| 1 | Foundation: | |
| | i. Depth below ground level | : 06ft below GL |
| | ii. Nature of Soil set out in the foundation level. | : Medium Gravel |
| | iii. Pressure at foundation | : 10 T/sqm |
| | iv. Probable safe bearing capacity of of the foundation | : 18 T/sqm |
| 2 | Super Structure | : Brick work in CM |
| | i. Maixmum Stress in most critical sections of masonry and concrete | : a) R.C.C. Concrete : 35 kg/ Sq.cm |
| | | : b)Masonry : 09 Tones/ Sq.m |
| | ii. Maixmum Stress in most critical sections of masonry and concrete | : a) Brick Masonry : 30 tones /Sq.m |
| | | : b) R.C.C. : 40 kg /Sq. cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875(Latest version) and other relevant Indian Standard Code of practices I declare that the building is structurally sound to be used a public building for the purposed noted in the statement.

This Certificate does not include any Thatched sheds and also any flammable building material utility. Proport toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid.

A License may be granted for the period from 20.06.2025 to 19.06.2028

Date : 23.05.2025.

Place: Vellore - 632 009.


Signature of the Engineer,
Er. M. Jagadeesan, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District

Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Valuer.
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvacahri,
Vellore – 632 009.
Phone: 0416 2252260.
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

" EDIFY SCHOOL" RAMALAI VILLAGE,

FORM OF CERTIFICATE OF STRUCTURAL UNDER SUB SECTION (B) OF SECTION OF (4) OF THE TAMILNADU
PUBLIC BUILDING (LOCENSING ACT 1965 TAMILNADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE
TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I certify that I have inspected the building mentioned in the statement and I furnish below its salient technical features.

- 1 Foundation:
 - i. Depth below ground level : 06ft below GL
 - ii. Nature of Soil set out in the foundation level. : Medium Gravel
 - iii. Pressure at foundation : 10 T/sqm
 - iv. Probable safe bearing capacity of of the foundation : 18 T/sqm
- 2 Super Structure : Brick work in CM
 - i. Maixmum Stress in most critical sections of masonry and concrete : a) R.C.C. Concrete : 35 kg/ Sq.cm
: b)Masonry : 09 Tones/ Sq.m
 - ii. Maixmum Stress in most critical sections of masonry and concrete : a) Brick Masonry : 30 tones /Sq.m
: b) R.C.C. : 40 kg /Sq. cm.


The Structural of the building has been verified by me with reference to ISIS loading standards 875(Latest version) and other relevant Indian Standard Code of practices I declare that the building is structurally sound to be used a public building for the purposed noted in the statement.

This Certificate does not include any. Thatched sheds and also any flammable building material utility. Proport toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid.

A License may be granted for the period from 20.06.2025 to 19.06.2028

Date : 23.05.2025.

Place: Vellore - 632 009.


Signature of the Engineer,
Er. M. Jagadeesan, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District

Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Valuer.
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvachari,
Vellore – 632 009.
Phone: 0416 2252260.
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

FORM -C

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

" EDIFY SCHOOL" RAMALAI VILLAGE,

Form of Certificate of structural soundness under sub section (b) of section of 4 of the Madras public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public Building Licensing) rules 1977.

Certify that I have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building, for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian Standard 875.

1. Location of the building Door No. : " EDIFY SCHOOL "
Street & Name of the place. : "DURASAMY MAHADEVAN EDUCATIONAL TRUST"
: S.F.Nos. 65/51A, 65/2B2B, 65/2C2 & 68/1D,
: Ramalai Village and panchayat,
: Gudiyatham Taluk,
2. Age of the building : Ground Floor & First Floor : RCC ; 6 years
3. Approximate cost of construction as per : ₹ 35,00,000
current rates
4. No. of Storeys : Ground Floor & First Floor
5. Shot description of Structure, steel, RCC : RCC Framed Structure.
framed / load bearing masonry.
6. Purpose for which the building is used or : Educational purpose
proposed to be used
7. The period for which the building will be : 20.06.2025 to 19.06.2028 (Three years only).
structurally sound
8. No. of Persons accommodated : Six Hundred (600) pupils only
9. Remarks. : The building is structurally sound.

Date: 23.05.2025.

Place: Vellore – 632 009



Signature of the Engineer.
Er. M. JAGADEESAN, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District
39, 3rd Main Road, Phase-I, TNHB, Sathuvachari,
Vellore - 632 009. Phone: 0416-2252260

Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Val
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvachari,
Vellore – 632 009.
Phone: 0416 2252260.
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

DECLARATION

I, Er. M. Jagadeesan, M.E.(Structural) MoV. , S/o. Late Mr. Muthuvel having office at No. 39, 3rd Main Road, First Floor, Phase-1, TNHB, Sathuvachari, Vellore City Corporation, Vellore Taluk, Vellore District - 632 009, do hereby declare that I Possess the qualification and experience specified in the Table Rule of 11 of Tamilnadu Public Building (Licensing) Rules 1966, for Issuing the certificate of Structural Soundness of the building covered by the certificate.

I am an empanelled Private Practicing Engineer in Vellore District under Tamilnadu Public Buildings (Licensing) Act 1965 to issue the Structural Soundness Certificate to Public Buildings like the school under reference.


Signature of the Engineer.
Er. M. JAGADEESAN, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District
#39, 3rd Main Road, Phase-I, TNHB, Sathuvachari,
Vellore - 632 009. ☎ : 0416-2252260

Note:

1. This certificate contains 5 pages and covers only the building mentioned therein not any other buildings, compound wall, other structures such as external sanitation, septic tank, water supply, sump etc in the premises.
2. Maintenance of the above buildings should be carried out periodically.
3. If the certificate is tampered illegally or made any corrections / alterations without permission, knowledge, of the undersigned, this certificate will automatically get cancelled.
4. This Certificate never covers and out of scope of any natural disasters like earthquake, cyclone, fire and any other impacts which affect the stability of the buildings mentioned in this certificate.
5. No structures with inflammable roofs must be allowed with the premises.

Date: 23.05.2025.

Place: Vellore – 632 009


Signature of the Engineer
Er. M. JAGADEESAN, M.E., MoV.,
Collector Approved Panel Engineer (Class-1A)
Vellore District
#39, 3rd Main Road, Phase-I, TNHB, Sathuvachari,
Vellore - 632 009. ☎ : 0416-2252260


Er.M.Jagadeesan, M.E., MoV.,
Chartered Engineer & Registered Valuer.
Collector Approved Panel Engineer (Class-1A)
Vellore District.

M J Associates.,
#39, (First floor) Third Main Road,
TNHB, Phase – I, Sathuvachari,
Vellore – 632 009.
Phone: 0416 2252260.
Mobile: 90920 49999
Email: valuerjagadeesan@gmail.com

FORM – E

1	Name and Designation of Inspecting authority or officer appointed or having jurisdiction under any other Act or Law	Er. M. Jagadeesan, Vellore District Empanelled private practicing Engineer.
2	Location of the building door No. street name and name of the place.	"EDIFY SCHOOL" "DURASAMY MAHADEVAN EDUCATIONAL TRUST " S.F.Nos. 65/51A, 65/2B2B, 65/2C2 & 68/1D, Ramalai Village and panchayat, Gudiyatham Taluk, Vellore District.
3	Date of Inspection.	Dt: 23.05.2025.
4	Purpose for which the building is certified for use	Educational purpose.
5	Nature of defects noticed.	Nil.
6	Suggestions for rectifying defects.	Not applicable.
7	If in a dangerous condition immediate steps recommended to be taken.	Nil.

Date :23.05.2025.
Place: Vellore - 632 009.


Signature of the Engineer
Er. M. JAGADEESAN, M.E., MoV.
Collector Approved Panel Engineer (Class-1A)
Vellore District
39, 3rd Main Road, Phase-I, TNHB, Sathuvachari,
Vellore - 632 009. ☎ : 0416-2252260